

## Chemical Splash Poster



- Laminated poster with wipeable surface
- Easy to follow instructions
- Size: 420 x 590mm

HS302

Mfrs. List No.	Order Code	1+	5+	10+	20+
A595	725-2286				

## First Aid Publications

**First Aid at Work**  
Your Questions Answered

HSE



- Ideal employee handout
- Guidance on resuscitation, broken bones, chemical burns, eyes, gassing and minor injuries
- Clearly illustrated and explained

HS634

15 Per Pack	Mfrs. List No.	Order Code	Price Per Pack
	0717610748	714-4180	1+

## Body Supports

**Back Support Belt**



- Fully adjustable back support belt
- Made of a lightweight nylon and lycra combination
- Does not restrict movement
- Detachable braces, attached with velcro fasteners
- Tapered from centre back to front for better fit
- Enclosed metal stays, on back inside portion of belt, helps eliminate belt slippage
- Fully washable

HS163

Size	Size	Waist	Order Code	1+	5+	10+
S	71-81cm	(28" - 32")	626-703			
M	81-96cm	(32" - 38")	626-715			
L	96-119cm	(38" - 47")	626-727			

## Smoke, Heat and Gas Detection

**Single-Station Battery-Powered Smoke Alarm**



- Ionisation smoke alarm
- Manual test button
- 85 dB alarm at 3m
- Supplied with zinc-carbon PP3 battery
- 30 day low battery warning
- 5 year guarantee
- Complies with BS 5446:P11:1990



Mfrs. List No.	Order Code	1+	5+	10+	25+
E1100BNX	709-7293				

HS473

## Manual Call Points - Resettable



Flush H = 88, W = 88, D = 27  
Surface H = 88, W = 88, D = 50

Contacts SPCO Mfrs. List No. YR/RN/S = 720-501,  
Contact rating 5A @ 250V ac/30V dc YR/RN/F = 720-513, YR/RN/G = 720-525



- Frangible element of call point is moulded plastic no fragments released on operation
- 4 operations before "glass" replacement
- No hammer required
- Re arming and testing is carried out by means of the key supplied with each unit
- Open or closed switch contacts
- Surface or flush mounting
- Conforms to **BS5839, part 2 1983**

Manual Call Point	Order Code	1+	10+	25+	50+
Surface mount	720-501				
Flush mount	720-513				
Spare glass (Pk of 4)	720-525	1+	5+	10+	

HS193

## Battery Powered Smoke and Fire Alarms

All battery powered smoke and fire alarms have the following features:-

- **Low Battery Warning:** Unit beeps approximately every 45 seconds for up to 30 days when the battery needs replacing
- **Operating Light (LED):** Flashes every 45 seconds (approx) confirming unit is powered.
- **Sensitivity Test Button:** Tests sensitivity, circuitry, battery, and horn
- **Loud 85 dB Piezo Electric Alarm:** Automatically resets when hazardous condition has passed
- **Manufactured using high quality solid state components**
- **Easy Installation:** Fixings supplied



The table below is intended as a guide for the selection of the most suitable model for each application.

MODEL	Micro 300/ Micro 300I	Micro 300AP	N 350	N 4401
Order Code	677-954	677-966	677-980	678-004
Bedrooms	●	■	■	■
Living Rooms	●	■	■	■
Kitchen	X	■	X	●
Stairway	■	■	●	■
Confined Areas	■	●	■	■

● Most Suitable ■ Suitable X Not Recommended

HS195

## Dual Ionisation - Standard, Linkable and Alarm Pause



Dia = 110, D = 32

- General purpose smoke and fire alarms
- **Linkable** version can be connected up to 11 other linkable units, all alarms will sound if any one alarm is activated
- **Alarm Pause** version allows the user to silence the alarm momentarily by pressing the test button, ideal when non-emergency smoke (eg cooking fumes) causes nuisance alarms

Mfrs. List No. MICRO N300 = 677-954,  
MICRO N300I = 677-978,  
MICRO N300AP = 677-966

FOR SUITABLE REPLACEMENT BATTERY ORDER CODE 279-298  
SEE PAGE 20

HS196

Smoke Alarm	Order Code	1+	5+	10+	50+
Standard	677-954				
Linkable	677-978				
Alarm Pause	677-966				

Continued