

# **JB26 Jumper Bars**

# **Terminal Blocks Accessories**





Screw jumper bars

Main Tech	nical Data		Mounting Instructions		Screw			
		IEC	cULus - CSA	Ех е	Tool		Allen Key Ø 4 mm	
Rated current		232 A	230 A				Ø 0.157 in	
Rated voltage	Standard use	1000 V	600 V	630 V	Torque		2 Nm ± 0.4	
	Alternated poles			Not authorized			17.7 lb.in ± 3.54	
Impulse withstand voltage		8000 V						
Protection		IP	NEMA					
Material Specifications		Flammability		Copper				
		NF F 16 101						
Ambient temperature min/max		Service IEC 60068-2-1		-55 +110 °C	-67 +230 F			
		Storage		-55 +110 °C	-67 +230 F			
		Installing						

### **Ordering Details**

JB26 Jumper Bars								
Description			Туре	Order Code	Pack <sup>(ing)</sup>	Pack <sup>(ing)</sup> Weight		
					pieces	<b>g</b> (1 pce)		
26 mm 1.02 in spacing	2 poles		JB26-2	1SNK 926 302 R0000	5	41.20		
	3 poles		JB26-3	1SNK 926 303 R0000	5	65.70		
	5 poles	_	JB26-5	1SNK 926 305 R0000	5	115.70		
	10 poles		JB26-10	1SNK 926 310 R0000	5	241.50		

## **JB26** Mounting Instructions



- With flat pliers, cut out the partitions on the terminal block insulating body.
  Be careful to not cut out the jumpered terminal blocks at both ends of the assembly,
- Mount the jumper bar with the recommended tool and torque.

